



Results Summary for Lead in Water Samples

School Name: Hope Community Charter School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
KS-01	13-0822-01	Church; Cafeteria; Kitchen sink	3.61	No
WF-01	13-0822-02	Church; hallway to cafeteria; WF	ND	No
KS-02	13-0822-03	Rectory; Kitchen; sink	3.27	No
WC-01	13-0822-04	Rectory; Kitchen; water cooler	ND	No
WC-02	13-0822-05	School; 1st Floor; rear corridor; WC	ND	No
WC-03	13-0822-06	School; 1st Floor; outside Nurse; WC	ND	No
NS-01	13-0822-07	School; 1st Floor; Nurse restroom; sink	1.11	No
WC-04	13-0822-08	School; 2nd Floor; rear corridor; WC	ND	No
WC-05	13-0822-09	School; 3rd Floor; rear corridor; WC	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)

ND = None Detected